

LOCATION 1205 Butler ST. CITY GASTONIA

BETWEEN Osceola ST STREET & Wagner Cir STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	77'			3-9-94
MAIN TO PROP. LINE	3/4"	P	3'			
PROP. LINE TO BLDG.	3/4"	P	74'			

ENTERS: 1205 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 40 P.S.I. INCHES W.C. LOCATION 160' E of center of

Osceola ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffel

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 14' S. of center of Butler ST

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY