

LOCATION 1205 Butler ST. 1 THUR S CITY GASTON, VA  
BETWEEN Butler CT STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	25'		3-14	-94
MAIN TO PROP. LINE	3/4"	P	5		241' of 3/4" CEW	
PROP. LINE TO BLDG.	3/4"	P	20'			

ENTERS: 1205 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I.        INCHES W.C. LOCATION 273' W. of center of  
Butler CT

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffplus  
MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1994  
DEPTH: 3 Ft.        In. LOCATION 14' S. of center of Butler ST.

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY