


LOCATION 1213 Butler ST CITY GASTONIABETWEEN Butler CT. STREET & Oscola ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	52'		3.	14-94
MAIN TO PROP. LINE	3/4"	P	5'		241' of 3/4" c/w	
PROP. LINE TO BLDG.	3/4"	P	47'			

ENTERS: 1213 BRANCHED INTO:TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 249' W. of center ofButler CT.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HuffelingerMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994DEPTH: 3 Ft. In. LOCATION 14' S. of center of Butler ST"A" P/S READING 7 TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY