

LOCATION 1214 Butler StCITY GASTONIABETWEEN OSCEOLASTREET & Butler Ct

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	CHW	EXIS ^{150'} 3/4" CHW	TIED OVER		
MAIN TO PROP. LINE			NEW 3/4" (3')	3-10-95		
PROP. LINE TO BLDG.						

ENTERS: 1214 1-G

BRANCHED INTO:

TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 15' south ofButlerPRESSURE TEST: @ 100 psi For 44 Hrs. By M. PaulMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 94DEPTH: 3 Ft. 0 In. LOCATION 226' W OF Butler Ct"A" P/S READING 1.1 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.1 CHW Riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY