

LOCATION 109 Button Bush Ct. CITY GASTONIA
BETWEEN End of Culdesack STREET & Red Oak Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>96'</u>	<u>4-26-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>81'</u>			

ENTERS: 109 Button Bush Ct. BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 337' 5" E of Red Oak Ct.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 33' E of Cuf Button Bush Ct.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: New Plastic Gas Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY