

LOCATION 1427 N. Caldwell CITY GASTONIA

BETWEEN SY Camore STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>90'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>		<u>2-22-00</u>	
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>60'</u>			

ENTERS 1427 BRANCHED INTO 0

TAP SIZE 3/8 PRESSURE 60 PSI INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1960

DEPTH 2 FT 0 IN LOCATION

"A" P/S READING 1.3 TOTAL ANODES 1# - 17# - LR #

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	