

LOCATION 825 Cameron Ave. CITY GASTONIA

BETWEEN N Weldon ST STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	118'	3-30-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	113'			

ENTERS: 825 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 40' E of center of

N. Weldon ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S Huffstetler

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1962

DEPTH: 3 Ft. 0 In. LOCATION 14' S. of center of Cameron Ave.

"A" P/S READING 1.6 TOTAL ANODES 1# 0 17# 6 L.R. # 145185

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY