

LOCATION 508 Cameron Pointe Ln. CITY GASTONIA

BETWEEN S. New Hope Rd. STREET & Cal-de-Sae. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	123'	7-18-96		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	83'			

ENTERS: 508 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 217' W. of center of
S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hunt-Stettin

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 20' S. of center of Cameron Pointe Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 371937

REMARKS:

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	