

LOCATION	516 Cameron Pointe Ln.		CITY	GASTONIA		
BETWEEN	S New Hope Rd.		STREET &	STREET		
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	125'	10-7-96		
MAIN TO PROP. LINE	3/4"	P	48'			
PROP. LINE TO BLDG.	3/4"	P	80'			

ENTERS: 516		BRANCHED INTO:	
TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 457' SW. of center of S. New Hope Rd.


PRESSURE TEST: @ 100 psi For 4 Hrs. By S. Huff Stitt

MAIN-SIZE 2"	C.I. <input type="checkbox"/>	BARE STEEL <input type="checkbox"/>	COATED STEEL <input type="checkbox"/>	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED
--------------	-------------------------------	-------------------------------------	---------------------------------------	---	----------------

DEPTH: 3 Ft. 0 In.	LOCATION 20' SE. of center of Cameron Pointe Ln.
--------------------	--

"A" P/S READING P	TOTAL ANODES 1# 0 17# 0	L.R. # 514870
-------------------	-------------------------	---------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY