

LOCATION S23 Cameron Pointe CITY Gastonia

BETWEEN S. New Hope Rd. STREET & Cul. de - Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>91'</u>	<u>5-16-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>86'</u>			

ENTERS: S23 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 600' S. of center of

S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstiller

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 20' E. of center of Cameron Pointe

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 275296

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY