

LOCATION 537 Cameron Pointe Ln. CITY CASTANIA
BETWEEN S. New Hope Rd. STREET & Cul-de-Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	80'	6-30-98		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP LINE TO BLDG.	3/4"	P	70'			

ENTERS: 537 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 930' W. of center of
S. New Hope Rd.

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY S. Harkins
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED
DEPTH: 3 FT 0 IN LOCATION 19' S. of center of Cameron Pointe Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 453958

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		