

LOCATION 544 CAMERON POINTE LNCITY GastoniaBETWEEN S. NEW HOPESTREET & DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>126'</u>	<u>10-16-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>81'</u>			

ENTERS: 544

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE _____ PSI

_____ INCHES W C

LOCATION 20' E. of Cap
Cameron PointePRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JPMAIN-SIZE 2"

C.I. _____

BARE STEEL _____

COATED STEEL _____

PLASTIC ☒YEAR INSTALLED 1995DEPTH: 3 FT. 0 IN.


LOCATION

"A" P/S READING P

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY