

LOCATION 553 Cameron Pointe Ln. CITY BASTON, MA

BETWEEN S. New Hope Rd. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>3-31-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>75'</u>			

ENTERS: 553 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 1276' SW. of center of S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY S. Huffstetter

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 21' SE. of center of Cameron Pointe Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 210476

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY