

LOCATION 557 Cameron Pointe Ln CITY GASTONIA

BETWEEN S. New Hope Rd. STREET & Cul-de-sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>84'</u>	<u>3-31-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>79'</u>			

ENTERS: 557 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 1371' SW. of center of

S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Hufstetler

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 21' SE of center of Cameron Pointe Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 210475

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY