

LOCATION 563 Cameron point Ln

CITY Gastonia

BETWEEN S. New Hope

STREET & Dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	103	2-17-96		
MAIN TO PROP. LINE	"	"	3			
PROP. LINE TO BLDG.	"	"	100			

ENTERS: 563

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 1574' W of C
of S. New Hope Rd

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC ☒

YEAR INSTALLED 1995

DEPTH: 3 Ft.

In.


LOCATION 43' S of Cot Cameron point

"A" P/S READING Plastic

TOTAL ANODES 1# - 17#

L.R. # 7A5P

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY