

LOCATION 3309 Candlewick Way CITY GASTONIA

BETWEEN Mossbank PL STREET & Springhouse Pt STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4" | P    | 105'   | 3-28-98   |         |         |
| MAIN TO PROP. LINE  | 3/4" | P    | 5'     |           |         |         |
| PROP. LINE TO BLDG. | 3/4" | P    | 100'   |           |         |         |

ENTERS: 3309 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 94' S. of center of Mossbank PL


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBLETT

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1988

DEPTH: 2 Ft. \_\_\_\_\_ In. LOCATION 20' W. of center of Candlewick Way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 136841

REMARKS:



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    |       |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY