

LOCATION 3401 Candlewick Way CITY GASTONIA

BETWEEN Silversmith Cir STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>83'</u>	<u>5-5-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS: 3401 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 33' N. of center of

Silversmith Cir


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By S. HUFFSTETTER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1988

DEPTH: 3 Ft. 0 In. LOCATION 19' W. of center of Candlewick Way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 212512

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY