

LOCATION 3409 Candlewick way CITY Gastonia
BETWEEN Silver Smith Cir STREET & Cat de Sae STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	86'	2-11-97		
MAIN TO PROP. LINE	3/4"	P	6'			
PROP. LINE TO BLDG.	3/4"	P	80'			

ENTERS: 3409 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 12' S. of center of
Silver Smith Cir

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. Huffstutler
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____
DEPTH: 3 FT 0 IN. LOCATION 20' W. of center of Candlewick way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 66480

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY