

LOCATION 3416 Candlewick way CITY GASTONIA

BETWEEN Silversmith Cir STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>134'</u>	<u>9-25-98</u>		
MAIN TO PROP. LINE	<u>3/4'</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>124'</u>			

ENTERS: 3416 BRANCHED INTO:

TAP SIZE 1/2 PRESSURE 60 PSI          INCHES W C LOCATION 201' S. of center of

Silversmith Cir.


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY S. Huffstetler

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED         

DEPTH. 2 FT 0 IN LOCATION 35' E of center of Candlewick way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 2056534

REMARKS

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		