

LOCATION 3417 Candlewick Way CITY Gastonia  
BETWEEN Silversmith CT STREET & Cut-ole - Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	99'	9-21-95		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	89'			

ENTERS: 3417 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 193' S. of center of  
Silversmith CT.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstater  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1989  
DEPTH: 2 Ft. 0 In. LOCATION 42' W. of center of Candlewick Way

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # 462570

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY