

LOCATION 1205 Candlewood Dr. CITY Gastonia

BETWEEN Candlewoods Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>104'</u>	<u>1-15-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>64'</u>			

ENTERS 1205 BRANCHED INTO

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 289' SW of center of

Candlewoods Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY Schulze

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 18' NW of center of Candlewood Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 35017

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY