

LOCATION 339 Cape Breton TRC CITY Cape Breton

BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>567'</u>	<u>4-20-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>567'</u>			

ENTERS: 339 BRANCHED INTO: \_\_\_\_\_

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 38' E of center of


\_\_\_\_\_ Driveway  
PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstader

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 6 In. LOCATION 13' N. of corner of Cape Breton TRC

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 172642

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY