

LOCATION 344 Cape Breton TRL.

CITY GASTONIA

BETWEEN Ingo nish

STREET & Louis Bourg Ct.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	98'	7-18-96		
MAIN TO PROP. LINE	3/4	Plastic	42'			
PROP. LINE TO BLDG.	3/4	Plastic	56'			

ENTERS: 344

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION 1100' E of C of Louis Bourg Ct.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC ✓

YEAR INSTALLED

1995

DEPTH: 4

Ft.

0

In.

LOCATION 17' N of C of Cape Breton TRL.

"A" P/S READING

Plastic N/A

TOTAL ANODES


1# 0

17# 0

L.R. #

385966

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY