

LOCATION 355 Cape Breton TRC CITY GASTON, N.S.

BETWEEN Igonish Dr. STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>85'</u> | <u>2-28-97</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>75'</u> | | | |

ENTERS: 355 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 656' NW. of center of

Igonish Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HURST

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 13' N. of center of Cape Breton TRC.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 93012

REMARKS.



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY