


LOCATION 364 Cape Breton TRLCITY DASTONIABETWEEN Ingonish Dr.STREET & Louisbourg

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>112'</u>	<u>10-20-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>40</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>72</u>			

ENTERS: 364BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 445' W of C of Ingonish Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995DEPTH: 3 Ft. 6 In. LOCATION 16' N of C of Cape Breton TRL -"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # 537786

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY