

LOCATION 368 Cape Breton TRL CITY GASTONIA
BETWEEN Ingonish STREET & Louis Bourg STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>89'</u>	<u>12-13-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>36'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>53'</u>			


ENTERS. 364 BRANCHED INTO: 36A
TAP SIZE: 3/4 Straight PRESSURE 60 PSI _____ INCHES W.C. LOCATION 450' W of C of Ingonish
P. Tee

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
~~PIPE~~ SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 2 FT. 0 IN LOCATION 90' S of C of Cape Breton TRL

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 711654

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY