

LOCATION 372 Cape Breton TRL CITY Cape Breton

BETWEEN Igonish DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	110'	4-15-96		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	70'			

ENTERS: 372 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 P.S.I. INCHES W.C. LOCATION 292' N. of center

of Igonish DR


PRESSURE TEST: @ 105 psi For 1/4 Hrs. By S. Hufferd

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 12' N. of center of Cape Breton TRL

"A" P/S READING P TOTAL ANODES 1# 17 # 0 L.R. # 177551

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY