

LOCATION 1063 Capel Ct.

CITY SAN ANTONIO

BETWEEN Plantation TRL

STREET & End of Culdesack

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	90'	8-22-96		
MAIN TO PROP. LINE	3/4	Plastic	10'			
PROP. LINE TO BLDG.	3/4	Plastic	80'			

ENTERS: 1063

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION 350' N of Cap Plantation TRL.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 45' W of Cap Capel Ct.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 L.R. # 456700

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY