

LOCATION 1066 Capel Ct CITY GASTONIA  
BETWEEN White Pond Rd STREET & Cut-de-Ste STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>88'</u>	<u>8-14-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>78'</u>			

ENTERS: 1066 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W C LOCATION 348' N. of center of  
White Pond Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler  
MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED           
DEPTH. 3 FT 0 IN LOCATION 44' W. of center of Capel Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 523640

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY