

LOCATION 509 CARL ST. CITY GAST.  
BETWEEN PEARL ST STREET & DUNN ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>73'</u>			<u>7-21-97</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>68'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W/C LOCATION 400' from E of PEARL ST

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY A.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN. LOCATION WEST side of CARL ST.

"A" P/S READING P TOTAL ANODES 1# — 17# — I.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY