

LOCATION 514 CARL St. CITY Gast.
BETWEEN DuHart St. STREET & Pearl St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>191'</u>		<u>7-</u>	<u>22-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>143'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 272' From @ OF
DuHart St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 0 IN. LOCATION West side of CARL St.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY