

LOCATION 515 CARL St. CITY EAST.
BETWEEN DUHART St. STREET & PEARL St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>33'</u>		<u>7-</u>	<u>22-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>17'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>16'</u>			

ENTERS: SAME BRANCHED INTO: 513 CARL St.

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 273' From @ of
DUHART St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION West side of CARL St.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY