

SPLIT
LOCATION 702 + 712 Carlton Dr.

CITY EASTONIA

BETWEEN GRAYSTON STREET & GARRISON BLVD. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	1'	5-21-94	Tied over 72' Existing 3/4" CW	
MAIN TO PROP. LINE					on 702 Carlton Dr	
PROP. LINE TO BLDG.					Tied over 156' Existing 3/4" CW on 712 Carlton	

ENTERS: 712 Carlton BRANCHED INTO: 702 Carlton

TAP SIZE: 1/2 PRESSURE: 60 P.S.I. INCHES W.C. LOCATION 229' S of E of Grayston


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 20' W of E of Carlton St.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS: Tied TRACED wire OFF AT Tee.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 702 1.1 Riser 712 1.1
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY