

LOCATION 918 Carmel Dr CITY Corvallis  
BETWEEN Union Rd STREET & Union Terrace STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>73'</u>	<u>Replaced</u>	<u>9-23-97</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 918 BRANCHED INTO: 2  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EP

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: 3 FT 0 IN LOCATION \_\_\_\_\_

"A" P/S READING 110 TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:  
Trace wire bonded to EXT 3/4 g/w pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser Plastic</u>	<u>110</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY