

LOCATION 100 CARMEL HILLS DR. CITY GASTONIA

BETWEEN Patrick Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>130'</u>	<u>2-9-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>90'</u>			

ENTERS: 100 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 100 P.S.I. _____ INCHES W.C. LOCATION 197' W. of center of

Patrick Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstuth

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. In. LOCATION 13' S. of center of Carmel Hills DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 43090

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY