

LOCATION 106 CARMEL Hills DRCITY GASTONIABETWEEN CAPELIA CTSTREET & PATRICK RD

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>150</u>	<u>11-29-95</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>36</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>"</u>	<u>114</u>			

ENTERS: 106

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.


LOCATION

S. of C ofCarmel Hills DRPRESSURE TEST: @ 100 psi For 1/2 Hrs. By SPMAIN-SIZE 2" C.I.     BARE STEEL     COATED STEEL     PLASTIC ☒ YEAR INSTALLED 1995DEPTH: 3 Ft. 0 In.

LOCATION

"A" P/S READING P TOTAL ANODES 1#     17#     L.R. #    

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY