

LOCATION 202 Carmel Hill's Dr CITY Gastonia

BETWEEN Capella Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>116</u>	<u>6-24-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>36</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>80</u>			

ENTERS: 202 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION South side of House


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By J. Moore

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 6 In. LOCATION 13 ft East center of st.

"A" P/S READING N/A TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY