

LOCATION 210 Camel Hills Dr. CITY GASTONIA

BETWEEN Winton Cr STREET & Patrick St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>95'</u>	<u>5-15-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60'</u>			

ENTERS: 210 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 80' E. of center of Winton Cr


PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY S. Hufferstien

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 10' S of center of Camel Hills Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 246221

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY