

LOCATION 306 CARMEL HILLS DR CITY CASTLETON

BETWEEN WATSON CT STREET & SUEGLAY CT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	105'	8-6-96		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	65'			

ENTERS: 306 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 212' W. of center of

WATSON CT


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HOFFER

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 12' S. of center of Carmel Hills Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 428178

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY