

LOCATION 309 Carmel Hills Dr CITY Castroville  
BETWEEN Suequay Cr STREET & Winton Cr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	57'	9-27-97		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	52'			

ENTERS: 309 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W C LOCATION 59' N. of center of Suequay Cr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstetler

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED         

DEPTH: 3 FT 0 IN. LOCATION 12' E of center of Carmel Hills Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 624215

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY