

LOCATION 402 Carmel Hills Dr. CITY GASTONIA  
 BETWEEN Blackburn Ct. STREET & 5th & 6th Sts. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>172'</u>	<u>9-22-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>80'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>92'</u>			

ENTERS 410 BRANCHED INTO 402  
 TAP SIZE 3/4 3way Tee PRESSURE 100 PSI INCHES W.C. LOCATION 324' N of C of Carmel Hills Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RC  
 SERVICE SIZE 3/4 C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996  
 DEPTH 2 FT 0 IN LOCATION 326' E of C of Blackburn Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 I.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

COPY