

LOCATION 2004 CAROL DRCITY GASTBETWEEN PAMELA ST

STREET &

LINDA ST

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>110'</u>		<u>6-12-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>60'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4PRESSURE 60 PSI _____ INCHES W.C.LOCATION 25 E FROM (C) OF PAMELA STPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY QWMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN LOCATION EAST SIDE OF PAMELA ST"A" P/S READING PTOTAL ANODES 1# — 17# —L.R. # —

REMARKS.



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY