

LOCATION 2019 CAROL DR

CITY

CASBETWEEN LINDA ST

STREET &amp;

PAMELA ST

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>167</u>		<u>6-11-97</u>	
MAIN TO PROP. LINE	<u>1</u>	<u>11</u>	<u>5</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>162</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE <u>3/4</u>	PRESSURE <u>60</u> PSI	INCHES W.C.	LOCATION <u>21' N</u> from <u>(C)</u> OF CAROL
---------------------	------------------------	-------------	--


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY QW

MAIN-SIZE <u>2"</u>	C.I. _____	BARE STEEL _____	COATED STEEL _____	PLASTIC <u>X</u>	YEAR INSTALLED <u>1997</u>
---------------------	------------	------------------	--------------------	------------------	----------------------------

DEPTH: 3 FT. 0 IN LOCATION NORTH SIDE OF CAROL

"A" P/S READING <u>P</u>	TOTAL ANODES 1# <u>—</u> 17# <u>—</u>	L.R. # <u>—</u>
--------------------------	---------------------------------------	-----------------

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY