

LOCATION 201 CAROLINA Ave CITY Carson
BETWEEN Jewett STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>16'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			<u>4-21-98</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>11'</u>			

ENTERS: 201 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 600 PSI INCHES W.C. LOCATION


PRESSURE TEST @ 100 PSI FOR 14 HRS BY EP

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1987

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:

	Test Station			<u>ENG. DEPT. USE ONLY</u>
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S	<i>0.175 V</i>	
	P/S Pipeline Lead - White Existing Main	E		