

LOCATION 216 CAROLINA Ave CITY CASTONIA
BETWEEN Central STREET & STREET


	SIZE	TYPE	LENGTH	Tie over	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	98'	3/7 1978		
MAIN TO PROP. LINE	3/4"		47'			
PROP LINE TO BLDG.	3/4"		51'			

ENTERS: 216 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION East side of 216

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH. 3 FT. 0 IN. LOCATION South side of CAROLINA Ave

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: tied over 95' of ex 3/4" plastic service to
new main with 3' of plastic pipe & tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY