

LOCATION 308 Caroline Ave CITY Spartanburg

BETWEEN Jewett St STREET & Westview St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>128</u>	<u>10-15-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>52</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>76</u>			

ENTERS: 308 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION East of house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Jewett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1987

DEPTH: 2 Ft. 6 In. LOCATION 27' S of J St

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # 00444565

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY