

LOCATION 503 CAROLINA Ave. CITY GASTONIA

BETWEEN Florida ST. STREET & S. York Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>163'</u>	<u>2-27-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>148'</u>			

ENTERS: 503 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 152' W. of center of S. York Rd.


PRESSURE TEST: @ 100 psi For 4 Hrs. By S. Huffsteter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH: 3 Ft. 0 In. LOCATION 12' S. of center of CAROLINA Ave.

"A" P/S READING .6 TOTAL ANODES 1* D17 * 1 L.R. # 79077

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY