

LOCATION 603 CAROLINA AVECITY GASTONIABETWEEN FloridaSTREET & Jackson

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>73</u>	<u>2-13-98</u>	<u>90' 3/4" CW</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5</u>		<u>1933</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>68</u>			

ENTERS: 603


BRANCHED INTO:

TAP SIZE: 3/4PRESSURE 60# PSI

INCHES WC

LOCATION 209' W OF FloridaPRESSURE TEST: @ 100 PSI FOR 4 HRS. BY M. ParkerMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 98DEPTH: 3 FT. 0 IN LOCATION 25' south of Carolina"A" P/S READING PTOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RISER</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY