


LOCATION 613 CAROLINA Ave CITY GATONIABETWEEN Florida St STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>78'</u>			<u>2/7/98</u>
MAIN TO PROP. LINE	<u>3/4"</u>		<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>63'</u>			

ENTERS: 613 BRANCHED INTO: 1TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION West side of 613PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DJMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN LOCATION South side of Carolina Ave"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY