


| | | | | | |
|---------------------|------------------|----------|---------|-------------------|---|
| LOCATION | 615 Carolina Ave | | | CITY GAITHERSBURG | |
| BETWEEN | JACKSON Rd | STREET & | FLORIDA | STREET | |
| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED <input checked="" type="checkbox"/> RENEWED |
| MAIN TO BLDG. | 3/4 | P | 127' | | |
| MAIN TO PROP. LINE | 3/4 | P | 20 | | 10-12-94 |
| PROP. LINE TO BLDG. | 3/4 | P | 107' | | |

| | | |
|---------------|---------------------|----------------------|
| ENTERS: 1615 | BRANCHED INTO: 1617 | |
| TAP SIZE: 5/8 | PRESSURE 20 P.S.I. | INCHES W.C. LOCATION |

| | | |
|--------------------------|---|---------------------|
| PRESSURE TEST: @ 100 psi | For 114 Hrs. | By [Signature] |
| MAIN-SIZE 2" | C.I. <input type="checkbox"/> BARE STEEL <input checked="" type="checkbox"/> COATED STEEL <input type="checkbox"/> PLASTIC <input type="checkbox"/> | YEAR INSTALLED 1930 |
| DEPTH: 3 Ft. 0 In. | LOCATION | |

| | | |
|---------------------|-----------------------|--------|
| "A" P/S READING 1.5 | TOTAL ANODES 1* 17* 1 | L.R. # |
|---------------------|-----------------------|--------|

| |
|----------|
| REMARKS: |
| |
| |
| |



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | 1.5 |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY